

SCHOOL LEAD MONITORING RESULTS  
 Mayfield Central Schools

<u>SAMPLE ID</u>	<u>SCHOOL &amp; SAMPLE LOCATION</u>	<u>DATE COLLECTED</u>	<u>LEAD mg/L</u>	<u>Date Analyzed</u> <u>Lead</u>
1608799	Mayfield High School 49 - Drinking Fountain 133	9/29/2016	<0.001	10/17/16
1608810	Mayfield High School 60 - Auditorium Drinking Fountain	9/29/2016	<0.001	10/17/16
1608794	Mayfield High School 44 - Boys Locker room Drinking Fountain	9/29/2016	0.0011	10/17/16
1608784	Mayfield High School 34 - Gym Drinking Fountain	9/29/2016	0.0012	10/17/16
1608791	Mayfield High School 41 - Girls Locker room Drinking Fountain	9/29/2016	0.0015	10/17/16
1608763	Mayfield High School 13 - 234 Sink 1	9/29/2016	0.002	10/17/16
1608803	Mayfield High School 53 - 304 Drinking Fountain	9/29/2016	0.0021	10/17/16
1608758	Mayfield High School 8 - 235 HC Wall	9/29/2016	0.0023	10/17/16
1608805	Mayfield High School 55 - 304 Ladies Room	9/29/2016	0.0024	10/17/16
1608790	Mayfield High School 40 - Ice Machine Slnk	9/29/2016	0.0028	10/17/16
1608765	Mayfield High School 15 - 233 Art Sink	9/29/2016	0.0031	10/17/16
1608773	Mayfield High School 23 - Slop Sink	9/29/2016	0.0037	10/17/16
1608785	Mayfield High School 35 - Gym Lobby Ladies	9/29/2016	0.0038	10/17/16
1608813	Mayfield High School 63 - 214	9/29/2016	0.0038	10/17/16
1608814	Mayfield High School 64 - 215	9/29/2016	0.004	10/17/16
1608775	Mayfield High School 25 - 225 Nurse Bathroom	9/29/2016	0.0047	10/17/16
1608804	Mayfield High School 54 -304 Mens Room	9/29/2016	0.0049	10/17/16
1608783	Mayfield High School 33 - 206 Sink 2	9/29/2016	0.0051	10/17/16
1608788	Mayfield High School 38 - 200 Super	9/29/2016	0.0051	10/17/16
1608795	Mayfield High School 45 - Boys Locker room Sink	9/29/2016	0.0051	10/17/16
1608757	Mayfield High School 7 - 321 Bathroom Sink	9/29/2016	0.0052	10/17/16
1608777	Mayfield High School 27 - 228 Chris	9/29/2016	0.0052	10/17/16
1608811	Mayfield High School 61 - Auditorium Mens	9/29/2016	0.0053	10/17/16
1608802	Mayfield High School 52 - 323 Drinking FOuntain	9/29/2016	0.0055	10/17/16
1608787	Mayfield High School 37 - 200 Ladies	9/29/2016	0.0061	10/17/16
1608801	Mayfield High School 51 - Faculty Bath Men	9/29/2016	0.0061	10/17/16
1608797	Mayfield High School 47 - 7th Ladies Room 1st Floor	9/29/2016	0.0062	10/17/16
1608782	Mayfield High School 32 - 206 Sink 1	9/29/2016	0.0066	10/17/16
1608751	Mayfield High School 1 - Kitchen Bathroom Sink	9/29/2016	0.0067	10/17/16
1608764	Mayfield High School 14 - 234 Sink 2	9/29/2016	0.0068	10/17/16

SCHOOL LEAD MONITORING RESULTS  
 Mayfield Central Schools

<u>SAMPLE ID</u>	<u>SCHOOL &amp; SAMPLE LOCATION</u>	<u>DATE COLLECTED</u>	<u>LEAD mg/L</u>	<u>Date Analyzed</u> <u>Lead</u>
1608769	Mayfield High School 19 - 236 Sink 2	9/29/2016	0.0068	10/17/16
1608780	Mayfield High School 30 - 2nd Floor Faculty Lounge	9/29/2016	0.0068	10/17/16
1608789	Mayfield High School 39 - 112	9/29/2016	0.0069	10/17/16
1608778	Mayfield High School 28 - 225 Office Sink	9/29/2016	0.0074	10/17/16
1608792	Mayfield High School 42 - Girls Locker room Sink	9/29/2016	0.0078	10/17/16
1608812	Mayfield High School 62 - Auditorium Ladies	9/29/2016	0.0081	10/17/16
1608766	Mayfield High School 16 - Jr High Drinking Fountain	9/29/2016	0.0083	10/17/16
1608770	Mayfield High School 20 - 239 ms bathroom boys	9/29/2016	0.0083	10/17/16
1608776	Mayfield High School 26 - 222 Drinking Fountain	9/29/2016	0.0088	10/17/16
1608756	Mayfield High School 6 - Line Sink Kitchen	9/29/2016	0.0089	10/17/16
1608755	Mayfield High School 5 - Kitchen Hand Wash Sink	9/29/2016	0.009	10/17/16
1608786	Mayfield High School 36 - Gym Lobby Boys	9/29/2016	0.0092	10/17/16
1608768	Mayfield High School 18 - 236 Sink 1	9/29/2016	0.0096	10/17/16
1608753	Mayfield High School 3 - Work Sink 2	9/29/2016	0.01	10/17/16
1608761	Mayfield High School 11 - 200 Library Sink Mens	9/29/2016	0.01	10/17/16
1608762	Mayfield High School 12 - 200 Library sink Ladies	9/29/2016	0.01	10/17/16
1608779	Mayfield High School 29 - 228 Main Office	9/29/2016	0.01	10/17/16
1608752	Mayfield High School 2 - Work Sink 1	9/29/2016	0.011	10/17/16
1608754	Mayfield High School 4 - Cooking Sink	9/29/2016	0.012	10/17/16
1608796	Mayfield High School 46 - 123	9/29/2016	0.012	10/17/16
1608808	Mayfield High School 58 - Allen's Room	9/29/2016	0.012	10/17/16
1608771	Mayfield High School 21 - 243 Sink 1	9/29/2016	0.015	10/17/16
1608798	Mayfield High School 48 - 7th Mens Room	9/29/2016	0.016	10/17/16
1608781	Mayfield High School 31 - Boys Bathroom Main	9/29/2016	0.017	10/17/16
1608759	Mayfield High School 9 - 235 HC Garage	9/29/2016	0.018	10/17/16
1608760	Mayfield High School 10 - 235 HC Parking Lot	9/29/2016	0.018	10/17/16
1608809	Mayfield High School 59 - 329	9/29/2016	0.023	10/17/16
1608774	Mayfield High School 24 - 252 Wall	9/29/2016	0.026	10/17/16
1608800	Mayfield High School 50 - 135	9/29/2016	0.027	10/17/16
1608767	Mayfield High School 17 - Custodial Closet	9/29/2016	0.028	10/17/16

JH CONSULTING, GROUP, INC  
PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

SCHOOL LEAD MONITORING RESULTS  
Mayfield Central Schools

<u>SAMPLE ID</u>	<u>SCHOOL &amp; SAMPLE LOCATION</u>	<u>DATE COLLECTED</u>	<u>LEAD mg/L</u>	<u>Date Analyzed</u> <u>Lead</u>
1608807	Mayfield High School 57 - 324 Wall	9/29/2016	0.03	10/17/16
1608793	Mayfield High School 43 - 126	9/29/2016	0.036	10/17/16
1608772	Mayfield High School 22 - 243 Sink 2	9/29/2016	0.041	10/17/16
1608806	Mayfield High School 56 - 324 Center	9/29/2016	0.043	10/17/16